

UL9540A Test Standard for IQ Battery 10T

Overview

As of 01/28/2022 Enphase has passed the UL9540A test for the Enphase IQ Battery 10T. The IQ Battery 3, 10, and 3T have already achieved this test standard and do not require any updates.

This standard allows the IQ Battery 10T to be installed closer than 36" apart in areas that require the UL9540A test standard, as per the Quick Install Guide. This requires an updated three-piece wall mount bracket assembly for the IQ Battery 10T, replacing the originally provided bracket provided in the cover kit. In order to receive and install a UL9540A-tested IQ Battery 10T from your distributor, installers must follow these instructions.

Ordering a UL9540A-Tested IQ Battery 10T

1. Order Details


Order the "IQ Battery 10T– Tested Parts" listed below through your distributor.

IQ Battery 10T- UL9540A Tested Parts

ITEM	SKU #	Part Description
NEW UL9540A TESTED PARTS		
1	B10T-AWM-1280-O	Enphase IQ Battery Additional Wall Mounts (AWM) <i>Includes top and bottom wall mount brackets.</i>
2	B10T-MWM-1280-O	Enphase IQ Battery Middle Wall Mount (MWM)
ORIGINAL PARTS (UNCHANGED)		
3	B03-T01-US00-1-3	Enphase IQ Battery Base Unit (Quantity: 3)
4	B10T-C-1290-O	Enphase IQ Battery 10T Cover Kit


Please note that both Item 1 and 2 must be ordered for the 10T to reach the UL9540A test standard. The image below shows how the new parts fit into a 3-piece assembly.

- When wall mounting an IQ Battery 10T tested for UL9540A, three items are needed
- They ship in two boxes, under two-part numbers



2. Quick Install Guides

- **KEEP** - Once you have received the shipment, please follow the [NEW Quick Install Guide](#) attached inside the box labeled "OPEN FIRST – NEW QUICK INSTALL GUIDE."



The box contains the Additional Wall Mounts (AWM's) and will have this sticker attached on the cover. The new quick install guide has a PN on the bottom left corner of the packet: 140-00176-07.

- **REMOVE** - There is an OLD Quick Install Guide located in the Base Unit Box labeled B03-T01-US00-1-3 that should be disposed of.

3. Updated Part

- **KEEP** - There will be a sticker labeled "UL9540A - NEW MWM Bracket," on the box containing an updated bracket you should keep.



- **REMOVE** - There is an old Middle Wall Mount (MWM) bracket located inside the Cover Kit box **B10T-C-1290-O**. The old MWM has more holes than the new MWM, and should be removed and disposed of.